Question 1: Item 9 requests the current physical capacity in Column 1. The response reports the number of licensed beds. While staff appreciates the comparison between the current number of licensed and the proposed capacity, please report the existing physical capacity as requested. Specify the location and current use of all physical bed capacity as was done in the 2009 CON application for a similar project. Complete the attached bed inventory spreadsheet.

Actual Physical Bed Capacity Before And After The Project

Washington Adventist Hospital 2013 Relocation CON

11/20/2013

| Location | | Existing Physical Capacity | | | | | After Project Completion | | | | | |
|---------------|--------------------|----------------------------|----------------|------------------|---------|----------------------|--------------------------|------------------|----------------|------------------|---------|----------------------|
| | | | Room Count | | | Bed Count | Location | | Room Count | | | Bed Count |
| (Floor/Wing) | Hospital Service | Licensed July, 2013 | Total Rooms | Semi- Private | Private | Physical Capacity | (Floor/Wing) | Hospital Service | Total Rooms | Semi- Private | Private | Physical Capacity |
| TCU LL 1 | MSGA (cv) | | 8 | 0 | 8 | 8 | | | | | | |
| 2200 2nd | MSGA (neuro/ortho) | | 30 | 9 | 20 | 38 | | | | | | |
| 2500 2nd | MSGA (cv) | | 17 | 14 | 3 | 31 | 3rd | MSGA (cv) | 32 | 0 | 32 | 32 |
| 3200 3rd | MSGA (oncology) | | 22 | 7 | 15 | 29 | 5th | MSGA | 32 | 0 | 32 | 32 |
| 4100 4th | MSGA | | 18 | 15 | 3 | 34 | 6th | MSGA | 32 | 0 | 32 | 32 |
| 4200 4th | MSGA | | 26 | 7 | 20 | 37 | 7th | MSGA | 32 | 0 | 32 | 32 |
| 5100 5th | MSGA (cv) | | 15 | 14 | 1 | 30 | 8th | MSGA | 24 | 0 | 24 | 24 |
| Subtotal MSGA | | 157 | 136 | 66 | 70 | 207 | | | 152 | 0 | 152 | 152 |
| 1500 ICU 1st | MSGA (ICU/CV) | | 16 | 0 | 16 | 16 | 2nd | ICU/CCU | 28 | 0 | 28 | 28 |
| 4300 ICU 4th | MSGA (ICU) | | 10 | 0 | 10 | 10 | | | | | | |
| 5300 5th | MSGA (CCU) | | 7 | 1 | 6 | 8 | | | | | | |
| Subtotal ICU | | 34 | 33 | 1 | 32 | 34 | | | 28 | 0 | 28 | 28 |
| Total MSGA | | 191 | 169 | 67 | 102 | 241 | | | 180 | 0 | 180 | 180 |
| 2100 2nd | Psych | 40 | 25 | 14 | 11 | 40 | TP | Psychiatric | 40 | 0 | 40 | 40 |
| 3100 3rd | ОВ | 21 | 20 | 10 | 10 | 30 | 4th | Obstetrics | 21 | 0 | 21 | 21 |
| Total | | 252 | 214 | 91 | 123 | 311 | Total | | 241 | 0 | 241 | 241 |

Note: Physical capacity is the total number of beds that could be accommodated without significant renovations. A room with two headwalls and two sets of gasses is a semi-private room, even if it is typically set up and operated with only one bed. A room with one headwall and one set of gasses is counted as a private room, even if it is large enough, from a square footage perspective, to be used as a semi-private room, since renovation/construction would be required to convert it to semi-private use. If the hospital operates patient rooms that contain a single headwall, but are used to accommodate more than one patient (e.g., for psychiatric patients), the physical capacity of such rooms is semi-private, and the bed capacity is as applicable.